1	Instruments and methods
2	
3	A dual sensor device to estimate fluid flow velocity at diffuse hydrothermal vents
4	
5	J. Sarrazin ^{a,*} , P. Rodier ^a , M.K. Tivey ^b , H. Singh ^b , A. Schultz ^c , P.M. Sarradin ^a
6	
7	^a Département Environnement Profond, Centre Ifremer de Brest, BP70, 29280 Plouzané, France
8	b Woods Hole Oceanographic Institution, Woods Hole, Massachusetts, 02543, USA
9 10	^c College of Oceanic and Atmospheric Sciences, Corvallis, Oregon, 97331-5503, USA
11	
12	* Corresponding author: E-mail address: jozee.sarrazin@ifremer.fr (J. Sarrazin).
13	Tel: +33 2 98 22 43 29, Fax: +33 2 98 22 47 57
14	
15	Abstract
16	Numerous attempts have been made over the last thirty years to estimate fluid flow
17	rates at hydrothermal vents, either at the exit of black smoker chimneys or within
18	diffuse flow areas. In this study, we combine two methods to accurately estimate fluid
19	flow velocities at diffuse flow areas. While the first method uses a hot film
20	anemometer that performs high frequency measurements, the second allows a
21	relatively rapid assessment of fluid flow velocity through video imagery and provides
22	in situ data to calibrate the sensor. Measurements of flow velocities on hydrothermal
23	diffuse flow areas were obtained on the Mid-Atlantic Ridge (MAR). They range from
24	1.1 to 4.9 mm/sec., at the substratum level, in low temperature (4.5 to 16.4°C) diffuse
25	flow areas from the Tour Eiffel sulfide edifice. A strong correlation was observed
26	between fluid flow velocities and temperature, supporting the possible use of
27	temperature as a proxy to estimate flow rates in diffuse flow areas where such a
28	simple linear flow/temperature relation is shown to dominate.
29	
30	Keywords
31	Fluid flow velocity, hydrothermal vent, hot film anemometer, video imagery, diffuse
32	flow
33	
34	

1. Introduction

36

37 High-temperature hydrothermal edifices at seafloor vent fields are particularly 38 complex and dynamic, offering to organisms a variety of potential habitats that range 39 from diffuse flow at near-ambient temperature to vigorously-venting hot smoker fluids. 40 Fluid composition and rates of fluid flow exiting at the chimney surface vary on the 41 same sulfide edifice, resulting in a complex mosaic of environmental conditions 42 available for organism colonization. The distribution of vent organisms is restricted to 43 regions where hydrothermal fluid interacts with seawater, providing both reduced and 44 oxygenated compounds essential to microbial primary producers (Jannasch and 45 Mottl, 1985; Childress and Fisher, 1992). The extreme dependence of vent 46 organisms on hydrothermal fluid supply (Desbruyères et al., 1985; Tunnicliffe et al., 47 1990) and, conversely, the relative toxicity of these fluids (Somero et al., 1989) 48 support a close link between the distribution of vent faunal assemblages and the 49 characteristics of the fluids (Van Dover, 1990; Sarrazin et al., 1997; Shank et al., 50 1998). Most evident is a trade-off between a nutritional dependence and tolerance to 51 harsh conditions (Chevaldonné, 2000; Shillito et al., 2001; Lee, 2003; Ravaux et al., 52 2003; Cosson et al., 2008). 53 Physico-chemical measurements of temperature, pH, and concentrations of sulfide, 54 methane and metals have been proposed to influence the spatio-temporal 55 distribution of hydrothermal fauna (Johnson and Tunnicliffe, 1985; Johnson et al., 56 1986, 1988a,b; 1994; Fisher et al., 1988a,b; Chevaldonné et al., 1991; Shank et al., 57 1998; Sarrazin et al., 1999; Desbruyères et al., 2001; Luther et al., 2001; Urcuyo et 58 al., 2003; Sarradin et al., 2008). Moreover, some authors have suggested that 59 microhabitat variation in hydrothermal fluid flux may have an important influence on 60 colonization by vent species (Desbruyères et al., 2000; Mullineaux et al., 2003) and 61 also on species distribution (Sarrazin et al., 1999). Gradients of hydrothermal fluid 62 flux may even influence successional processes at deep-sea vents (Sarrazin et al., 1997; Sarrazin et al., 1999; Sarrazin et al., 2002; Mullineaux et al., 2003). 63 64 Nevertheless, only a few attempts of quantitative fluid flow-rate measurement at the 65 scales of vent faunal assemblages have been made (Schultz et al., 1992, 1996; 66 Ramondenc et al., 2006). The majority of efforts have concentrated on discrete high -67 temperature hydrothermal discharges or on large diffuse-flow areas on the seafloor to 68 estimate large-scale heat flow output (Corliss et al., 1979; Converse et al., 1984;

70 et al., 1994; Trivett and Williams, 1994; Lavelle et al., 2001; Pruis and Johnson, 71 2004; Ramondenc et al., 2006). 72 A number of different methods have been used since the discovery of vents, starting 73 with visual observations using a vane-type flow meter from the Alvin submersible 74 (Corliss et al., 1979). Later on, turbine flow meters combined with temperature-probe 75 data allowed the measurement of fluid flow velocities exiting from high-temperature vents (Converse et al., 1984; Ginster et al., 1994). After calibration in the laboratory, 76 77 the turbine flow meter was held 3 cm above the fluid exit to limit jamming of the 78 turbine by small particles and to prevent melting of the plastic insulation. 79 Measurements at diffuse-flow areas include those of Schultz et al. (1992); they 80 obtained a 45-day time-series of flow rate on a diffuse flow area colonized by 81 siboglinid tubeworms using an electromagnetic-induction flow meter that was 82 calibrated in situ during the descent of the submersible. A later design, the MEDUSA 83 device, was developed by Schultz et al. (1996). It measures temperature and velocity 84 of hydrothermal effluents by means of a titanium rotor, whose spin rate is detected 85 optically. However, it was shown that the sensor was significantly affected by fouling 86 during long-term deployment. An alternative method, visual tracking of particles and 87 eddies in the ascending fluids, was used by Rona and Trivett (1992) and Ramondenc 88 et al. (2006). Both used a graduated rod placed above the vent orifice. Fluid velocity 89 was estimated through video imagery which requires the presence of eddies and 90 particles and does not allow for autonomous long-term measurements. 91 Measurement of fluid flow rate is also a challenge in cold-seep studies. As flow rates 92 are lower and environmental constraints lighter, the sensors are based on different 93 principles. For example, Linke et al. (1994) initially used a mechanical mass-flow 94 meter (Bernoulli type) calibrated as a function of temperature, pressure and salinity. 95 The sensor was subsequently replaced by a thermistor flow meter that can measure velocities from 0.01 to 50 cm s⁻¹. Tryon et al. (2001) used a chemical and aqueous 96 97 transport meter measuring the degree of dilution of a chemical tracer injected by an 98 osmotic pump at a known rate. This device is capable of measuring a serial record of 99 flow rates through the sediment surface up to 15 m yr⁻¹. 100 The major objective of our study was to build a reliable tool to measure fluid flow 101 velocities on small-scale hydrothermal diffuse flow areas. We have developed a dual 102 sensor approach to overcome harsh environmental constraints and to allow in-situ

Rona and Trivett, 1992; Schultz et al., 1992, 1996; Baker and Cannon, 1993; Ginster

calibration. Fluid flow velocities were obtained by combining hot film anemometer measurements with visual estimates of particle ascent through video imagery. The first results using this dual sensor, obtained at the Lucky Strike vent field at 37°17'N on the Mid-Atlantic Ridge (MAR), are presented.

2. Materials and methods

2.1. Fluid flow devices

103

104

105

106

107

108

109

131

a. The Flow Visualizer

110 A new instrument, designed at Ifremer with the help of the Remotely Operated 111 Vehicle (ROV) Jason engineers (Woods Hole Oceanographic Institution 1998), was developed to estimate fluid flow velocity. This "Flow Visualizer" is composed of a 112 113 transparent, 2-cm interval graduated pipe mounted on a large cylindrical chamber 114 (300 mm Internal Diameter; Figure 1). Flow rate is determined by placing the device 115 on selected diffuse-flow areas and by measuring particle ascent velocity within the 116 pipe using video imagery. Individual particles are located by the observer, and their 117 ascending time is recorded using the time code available on the video. Their travel 118 distance is evaluated by using the 2-cm-spaced graduations of the pipe. The 119 observer records the time that it takes for each visible particle to reach the top of the 120 cylinder. 121 The variability due to the observer was examined with two Wilcoxon signed ranked 122 tests for paired samples (Table 1). Because several particles are regularly passing 123 through the graduated tube, each observer does not necessarily select the same 124 ones. The first test was done to evaluate difference in the mean velocity measured by 125 two observers between different video sequences, regardless of the particles chosen. 126 The second was done to assess difference in the measured velocity for common 127 particles between two observers. The specific particles every observer measured 128 were identified by noting the time each particle entered the flow tube. This was done 129 for three paired data sets (OBS1 vs. OBS2, OBS1 vs. OBS3 and OBS2 vs. OBS3), 130 testing three different observers.

b. The flow sensor

The heated thin film flow sensor used (Figure 2) was delivered by Earth-Ocean Systems Ltd. The sensor is a Constant Voltage Anemometer type (CVA). This device employs two thin-film Pt resistive temperature sensors and a precision surface-mount resistor used as a heating element, contained within a paddle made of epoxy. The voltage applied to the heating element is constant. The sensor is immersed in the hydrothermal effluent. The upstream temperature sensor measures the ambient temperature (Ta), whereas the second, coupled thermally to the heater, measures the hot film temperature (Tw). The difference between Ta and Tw is proportional to the effluent flow rate, reflecting the increasing quantity of heat advected away from the thermal sensors in proportion to the increasing flow rate of the effluent.

143

144

145

146

147

148

149

150

151

152

153

154

155

156

157

158

159

160

161

162

163

132

133

134

135

136

137

138

139

140

141

142

c. Dual system -The FLO

The Flow Visualizer and the flow sensor were combined in a single instrument, named FLO, to perform a cross-comparison of the two methods. The dual system is composed of a transparent 2-cm graduated tube mounted on a chamber (Figure 1). A honeycomb material consisting of cells that are 3 mm in diameter was placed inside the chamber to regularize the flow regime. The flow sensor was set at the base of the tube in an elliptical nozzle. A flexible rubber skirt was used to seal the bottom of the chamber and limit leakage when the instrument was deployed on irregular surfaces. The size and shape of all of the elements composing the FLO were determined according to hydrodynamic constraints. The objective was to obtain a laminar (no turbulence) and uniform (flat velocity profile) flow at the sensor level. First of all, the pipe inner diameter (50 mm) was determined by the sensor size. To avoid disturbance at the measurement level, the length of the pipe was set at 500 mm to reach 10 times the inner diameter. The nozzle, mounted between the pipe and the chamber, insures a flat velocity profile. The ratio between the diameter of the chamber and that of the pipe (6:1) was calculated to amplify the velocity values obtained by the sensor (sensitivity gain). Therefore, to obtain the velocities at the substratum level, the results have to be divided by 37.6. The honeycomb layer was placed at 150 mm, which corresponds to half the chamber diameter, to insure a homogeneous flow at the nozzle inlet (Figure 1). The honeycomb should not have

- any hydrodynamic influence except for regulating the flow. The data-logger and
- battery are included in a titanium housing, rated up to 6000 m.
- The FLO is deployed by the manipulator arm of a ROV on a targeted sampling area
- 167 (Figure 3). The instrument must be placed on a relatively flat surface, and the pipe
- has to be vertical (more or less 10°). Once the instrument is set, the ROV main
- camera is focused and video imagery of the fluids ascending through the pipe is
- 170 recorded for a few minutes. The sampling time was optimized to 10 minutes per
- sampling area for the MoMARETO cruise (2006). The FLO can work autonomously
- for up to 24 hours.

173

2.2. Modeling the sensor response

- To characterize the relationship between fluid flow velocity (U), fluid temperature (Ta)
- and the hot film temperature (Tw), the formula of a Constant Voltage Anemometer
- 176 (CVA) (King 1914) is used.

177 (eq. 1)
$$f(U) = A + B \cdot U^n$$

- 178 Where U is flow velocity, and A, B and n are constants.
- 179 The PDR method, ratio of Power dissipated in hot-wire to the Difference in the
- 180 Resistance (Sarma & Comte-Bellot, 2002; Truzzi et al. 2002) states that:

181 (eq. 2)
$$\frac{P_{w}}{\left(R_{w}-R_{a}\right)}=A+B\cdot U^{n}$$
 with: $P_{w}=\frac{E_{w}^{2}}{R_{w}}$

- where Pw is the power dissipated in the heating element, Ew is the constant voltage
- applied to the hot-wire, Rw is the resistance of the heating element and Ra is the
- resistance in ambient conditions. The two equations become:

185 (eq. 3a)
$$U^{n} = \left(\frac{E_{w}^{2}}{B}\right) \cdot \frac{R_{w}^{-1}}{R_{w} - R_{a}} - \left(\frac{A}{B}\right)$$

- Since the sensor resistances are temperature dependent, the wire temperature T_w
- and the fluid temperature T_a are implicitly represented through R_w and R_a . The other
- terms of the formula are constants, so we may set $C=E_w^2/B$ and D=-A/B. Then
- 189 equation 3a can be written as:

190 (eq. 3b)
$$U^{n} = C \cdot \frac{T_{w}^{-1}}{T_{w} - T_{a}} + D$$

This theoretical equation was empirically transformed to better match the sensor response obtained in our experimental design. Therefore, the best curve fit is obtained with n=1 and by applying a power law (m) to the ratio of T_w over the temperature compensation term $(T_w$ - $T_a)$. With these modifications, the response model of our sensor becomes:

196 (eq. 4)
$$U = C' \cdot \frac{T_w}{(T_w - T_a)^m} + D'$$

with C', D' and m as calibration constants.

198

199

200

201

202

203

204

205

206

207

208

209

210211

212

213

In order to find these calibration constants, we used a specifically designed calibration device (an upside down version of the FLO; Figure 4). The calibration device uses Bernoulli & Torricelli gravity principles. It consists of a plane-parallel water tank regulated at a constant level by an overflow pipe (Figure 4). The flow sensor is inserted at the entrance of the outlet pipe. The flow is calmed upstream of the sensor by a honeycomb structure and regulated downstream by a needle valve. The geometry of the calibration device has been calculated to limit hydrodynamic disturbances as for the FLO instrument. The flow rate is calculated by recovering and weighing the water passing through the system during a measured period. The velocity is then deduced by dividing the flow rate by the cross sectional area at the sensor level. Temperatures are obtained by the calibrated flow sensors. A series of regulated ambient temperatures (Ta: 17.5 to 35.3°C) and flow velocities (18 mm s⁻¹ to 160 mm s⁻¹) were used to obtain the different response curves (Figure 5). The coefficients C', D' and m, which are sensor-specific, are estimated using the Marquardt non-linear regression method (Statgraphics Plus software© version 5.1). For the sensor used to generate the response curves in Figure 5, we found:

214 (eq. 5)
$$U = 875.712 \cdot \frac{T_w}{(T_w - T_a)^{3.24614}} - 3.84287$$

This equation describes the curves seen in Figure 5 and the results from the calibration give the data shown in Figure 6. Calibration coefficients can also be

determined in the field, using velocity measurements from video imagery as a reference.

2.3. At-sea trials

The first in-situ use of the FLO was carried out during the EXOMAR cruise on the RV L'Atalante with the ROV *Victor6000* (2005) on the Tour Eiffel edifice located within the Lucky Strike vent field on the Mid-Atlantic Ridge. Four trials were done allowing validation of the system deployment by the ROV, refinement of the method, and the acquisition of two series of data using the visual approach only (because of failure of the sensor).

The second use of the FLO, with a new sensor that was calibrated in the field, was during the MoMARETO cruise (R/V Pourquoi pas?/ROV *Victor6000*, Sarrazin et al., 2006). The system was deployed during four dives on the same sulfide edifice (Figure 3). In addition to the temperature taken by the flow sensor (Ta), ambient seawater temperature measurements were acquired with the ROV's temperature probe and with autonomous probes (NKE®, France). All data sets (video,

233 temperature) were synchronized with the *Victor6000* internal clock.

3. Results

3.1 Observer effect

Six to nine video sequences from three dives were analyzed. Results of the first Wilcoxon test show that the mean velocity estimates from OBS3 was statistically different from that of the two others when using all data available (Table 1). Results of the second Wilcoxon test for particle velocities showed that no statistical difference between the three observers is observed when using the same particles (Table 1). These results validated the robustness of the visual method to evaluate particle speed regardless of the observer. The differences observed in the first test were probably due to difference in particle selection between the three observers. An optimal protocol would take the mean of velocity estimates obtained by two or more observers, regardless of the particles they choose. This will lead to better estimates of the fluid velocities observed in the field.

3.2 Data acquisition and sensor post-calibration

250 Fourteen data sets, coupling sensor measurements and video imagery, were 251 obtained and processed. The two temperature probes (T_a and T_w) were calibrated on 252 board. The data were acquired every five seconds. The duration of a measurement, 253 gathering both video and sensor data, varied from 0.5 to 10 minutes per sampling 254 site. No leakage was observed at the base of the FLO skirt during these 255 measurements. Unfortunately, the video images were only usable for 8 of 14 deployments. On the other sequences, the amount of particles was insufficient to 256 257 obtain reliable data. In addition, sensor data were lost because of power failure 258 during dive 305. 259 The calibration of the new sensor was done using the velocity measurements from 260 video imagery as reference. The coefficients of equation 4 for the new sensor. 261 calibrated in the field, were found by combining ambient temperature (T_a), hot film

calibrated in the field, were found by combining ambient temperature (T_a) , hot film temperature (T_w) and fluid flow velocity estimated from video imagery. The mean temperature values $(T_a$ and $T_w)$ were calculated from the stabilized part of the sequence (see example in Figure 7). The resulting equation, giving the flow velocity

U, measured by the flow sensor becomes:

266 (eq. 6)
$$U = 16.3399 \cdot \frac{T_w}{(T_w - T_a)^{0.230206}} - 60.5588$$

The differences in calibration coefficients (equations 5 and 6) are due to the use of two slightly different sensors.

The sensor flow velocity was calculated for all data sets, including the deployments where no video was available (Table 2). The flow rate was deduced from the sensor flow velocity using the internal dimensions of the FLO structure (30 cm skirt diameter and thus 706.9 cm² area at the base of the FLO structure and 18.8 cm² free section at sensor level).

274

275

276

277

278

279

269

270

271

272273

249

3.3 Temperature and velocity data

The ambient temperature (T_a) measured in the diffuse flow areas ranges between 4.5 and 16.4°C for a surrounding seawater temperature of 4.4°C. The hot film temperature (T_w) varied from 8.7 to 20.0°C. The flow velocities extracted from video analyses and used for calibration varied from 56.8 to 161.5 mm s⁻¹, and the

calculated flow velocities, extracted from the sensor data, varied from 41.9 to 183.6 mm s⁻¹ at the sensor level and from 1.1 to 4.9 mm s⁻¹ at the substratum level (Table 1). The calculated flow rates extend from 66.2 to 293 L min⁻¹ m⁻². Figure 7 gives an example of the fluid velocity data obtained during the fourth deployment of dive 304.

4. Discussion/conclusion

Within hydrothermal vent fields, the distribution of faunal assemblages may be influenced significantly by small-scale variations in fluid flow (Schultz et al., 1992; Sarrazin and Juniper, 1999). In this study, we combine two methods to accurately estimate fluid flow rates on diffuse flow areas. The first uses a heat-flow sensor, and the second measures fluid flow rates with visual estimates of particle ascent through video imagery. They are complementary: whereas the visual technique allows a relatively rapid assessment of fluid flow velocity, the flow sensor performs high-frequency measurements and provides temperature data. Nevertheless, the use of this sensor is sensitive to environmental temperature changes because its principle is based on temperature measurements. The dual approach is a convenient means to overcome this limitation by using video imagery to acquire discrete fluid-velocity estimates for post-calibration.

The dual approach used in this study allowed us to gather reliable measurements of flow velocities on a hydrothermal edifice on the mid-Atlantic ridge. Comparisons with other studies remain difficult because the measurement methods vary (direct versus indirect) and only a few measurements consider the surface studied (Table 3). Ideally, to be comparable, fluid velocity and fluid flow rate data should take the surface into account and include a detailed description of the type of fluid emissions (discrete versus diffuse).

Our measured flow velocities (at the sensor level) fall within the ranges observed by Rona and Trivett (1992) and Ramondenc et al. (2006) at low-temperature diffuse venting sites (Table 3). Nevertheless, these data do not inform about the emissions at the substratum level, reflecting the conditions experienced by the fauna. Data at the substratum level are scarce. Those obtained by Schultz et al. (1996) in a single diffuse flow site at TAG (Mid-Atlantic Ridge) give a particularly weak fluid velocity for a quite constant temperature (Table 3). The discrete velocity data obtained within this

study at the substratum level are comparable. Nevertheless, they differ greatly from those found in diffuse flow sites from the Juan de Fuca Ridge (Schultz et al. 1992), highlighting the heterogeneity of the vent environments. Moreover, measured flow rates from high-temperature exits can be up to 30 times higher than flow rates obtained in diffuse flow sites (Table 3).

One notable result of this study is the strong linear relationship between the ambient temperature and the flow rate in low-temperature areas (4.7-16.4°C, Figure 8). This correlation is in accordance with the buoyant plume theory mentioned by Schultz et al. (1992) for sites where diffuse hydrothermal fluids are of shallow, near-seafloor origin. According to this theory, the flow dynamics of such fluids should be governed primarily by the buoyancy of hot fluids rather than by poroelastic Darcy flow. Additional measurements are now required to corroborate the data acquired during this study and to refine the relationship between fluid flow velocity and temperature over a larger range and at variable tide cycles.

In areas where the relationship between temperature and flow velocity is verified, temperature can be used as a proxy to estimate fluid flow rates within different faunal assemblages. Thus, not only temperature may be used as a key-parameter to estimate the chemical composition of the fluids (Sarradin et al., 2008) but also other factors linked to fluid flow rates that could be of ecological significance. Nevertheless, while the FLO may be useful for measuring fluid flow rate in most hydrothermal communities (alvinellid, gastropod and mussel assemblages), it would require a major adaptation to measure fluid flow in long tube worm communities. Ultimately, the energy budget required to sustain chemosynthetic processes within different faunal assemblages could be estimated through extrapolation of discrete flow-rate measurements (Martins et al., 2008).

Acknowledgements

- We would like to thank the captain Philippe Guillemet of the R/V Pourquoi pas? and his crew for their essential collaboration to the success of the MoMARETO cruise.
- We also acknowledge the *Victor6000* pilots for their patience and constant support.
- Part of this cruise was funded by the EXOCET/D European project, contract #

GOCE-CT-2003-505342. The dual system was first tested during the EXOMAR cruise (2005) led by Anne Godfroy (Ifremer). As this work was initiated in Woods Hole, we would like to thank the ROV pilots of Jason who helped design the flow visualizer. We are particularly thankful to Andy Bowen, Will Sellers and Matt Heintz for their help building the flow visualizer, to Dan Fornari for his help and advice with the Vemco probes, to Gene Terray for good conversation about fluid dynamics and to Olivier Gauthier for the great statistical help. The first part of this research was sponsored by a NOAA/NURP grant award #NA96RU0221 and NSF grant OCE-9901563 to MKT and JS. JS was also supported by a FCAR (Quebec) post-doctoral fellowship. The last part of the project was supported through the ANR DEEP OASES (ANR06 BDV005).

356 357 **F**

References

- Baker, E.T., Cannon, G.A., 1993. Long-Term Monitoring Of Hydrothermal Heat-Flux Using
- Moored Temperature Sensors, Cleft Segment, Juan de Fuca Ridge. Geophys. Res.
- 360 Lett. 20 (17), 1855-1858.
- Chevaldonné, P., Desbruyères, D., Le Haître, M., 1991. Time-series of temperature from
- three deep-sea hydrothermal vent sites. Deep-Sea Res. 38 (11), 1417-1430.
- Chevaldonné, P.F., C.R. Childress J.J. Desbruyères, D. Jollivet, D. Zal, F. Toulmond, A.,
- 2000. Thermotolerance and the "Pompeii worms". Mar. Ecol. Prog. Ser. 208, 293-295.
- 365 Childress, J.J., Fisher, C.R., 1992. The biology of hydrothermal vent animals: physiology,
- biochemistry and autotrophic symbioses. In: Barnes, M., A.D. Ansell, Gibson, R.N.
- 367 (Eds.), Oceanogr. Mar. Biol. Ann. Rev. UCL press, pp. 337-441.
- 368 Converse, D.R., Holland, H.D., Edmond, J.M., 1984. Flow rates in the axial hot springs of the
- East Pacific Rise (21°N): implications for the heat budget and the formation of massive
- 370 sulfide deposits. Earth Planet. Sci. Lett. 69, 159-175.
- Corliss, J.B., Dymond, J., Gordon, L.I., Edmond, J.M., Von Herzen, R.P., Ballard, R.D.,
- Green, K., Williams, D., Bainbridge, A., Crane, K., Van Andel, T.H., 1979. Submarine
- thermal springs on the Galapagos rift. Science 203 (n°4385), 1073-1083.
- Cosson, R.P., Thiébaut, É., Company, R., Castrec-Rouelle, M., Colaço, A., Martins, I.,
- Sarradin, P.-M., Bebianno, M.J., 2008. Spatial variation of metal bioaccumulation in the
- 376 hydrothermal vent mussel *Bathymodiolus azoricus*. Mar. Env. Res. 65 (5), 405.
- Desbruyères, D., Gaill, F., Laubier, L., Fouquet, Y., 1985. Polychaetous annelids from
- 378 hydrothermal vent ecosystems: an ecological overview. Biol. Soc. Wash. Bull. 6, 103-
- 379 116.
- Desbruyères, D., Almeida, A., Biscoito, M., Comtet, T., Khripounoff, A., Le Bris, N., Sarradin,
- P.M., Segonzac, M., 2000. A review of the distribution of hydrothermal vent
- communities along the Northern Mid Atlantic Ridge: Dispersal versus environmental
- 383 controls. Hydrobiol. 440, 201-216.
- 384 Desbruyères, D., Biscoito, M., Caprais, J.C., Colaço, A., Comtet, T., Crassous, P., Fouquet,
- Y., Khripounoff, A., Le Bris, N., Olu, K., Riso, R., Sarradin, P.M., Segonzac, M.,
- Vangriesheim, A., 2001. Variations in deep-sea hydrothermal vent communities on the
- 387 Mid-Atlantic ridge near the Azores plateau. Deep-Sea Res. 48, 1325-1346.
- 388 Fisher, C.R., Childress, J.J., Arp, A.J., Brooks, J.M., Distel, D., Favuzzi, J.A., Felbeck, H.,
- Hessler, R., Johnson, K.S., Kennicutt II, M.C., Macko, S.A., Newton, A., Powell, M.A.,
- 390 Somero, G.N., Soto, T., 1988a. Microhabitat variation in the hydrothermal vent mussel,
- 391 Bathymodiolus thermophilus, at the Rose Garden vent on the Galapagos Rift. Deep-
- 392 Sea Res. 35, 1769-1791.

- Fisher, C.R., Childress, J.J., Sanders, N.K., 1988b. The role of vestimentiferan hemoglobin in
- 394 providing an environment suitable for chemoautotrophic sulfide oxidizing
- endosymbionts. Symbiosis 5, 229-246.
- 396 Ginster, U., Mottl, M.J., Vonherzen, R.P., 1994. Heat-Flux From Black Smokers On The
- Endeavor And Cleft Segments, Juan-De-Fuca Ridge. J. Geophys. Res. 99 (B3), 4937-
- 398 4950.
- 399 Jannasch, H.W., Mottl, M.J., 1985. Geomicrobiology of deep-sea hydrothermal vents.
- 400 Science 229, 717-725.
- Johnson, H.P., Tunnicliffe, V., 1985. Time-series measurements of hydrothermal activity on
- 402 northern Juan de Fuca Ridge. Geophys. Res. Lett. 12, 685-688.
- 403 Johnson, K.S., Beelher, C.L., Sakamoto-Arnold, C.M., Childress, J.J., 1986. In situ
- 404 measurements of chemical distributions in a deep-sea hydrothermal vent field. Science
- 405 231, 1139-1141.
- Johnson, K.S., Childress, J.J., Beelher, C.L., 1988a. Short time temperature variability in the
- 407 Rose Garden hydrothermal vent field: an unstable deep sea environment. Deep-Sea
- 408 Res. 35, 1711-1721.
- Johnson, K.S., Childress, J.J., Beelher, C.L., Sakamoto, C.M., 1994. Biogeochemistry of
- 410 hydrothermal vent mussel communities: the deep sea analogue to the intertidal zone.
- 411 Deep Sea Res. 41, 993-1011.
- Johnson, K.S., Childress, J.J., Hessler, R.R., Sakamoto-Arnold, C.M., Beelher, C.L. 1988b.
- 413 Chemical and biological interactions in the Rose Garden hydrothermal vent field,
- 414 Galapagos spreading center. Deep-Sea Res. 35, 1723-1744.
- 415 King, L. V. 1914. On the convection of heat from small cylinders in a stream of fluid:
- 416 Determination of the convection constants of small platinium wires with applications to
- 417 hot-wire anemometry. Phil. Trans. Roy Soc. A214, pp. 373-432.
- 418 Lavelle, J.W., Wetzler, M.A., Baker, E.T., Embley, R.W., 2001. Prospecting for hydrothermal
- vents using moored current and temperature data: Axial Volcano on the Juan de Fuca
- 420 Ridge, northeast Pacific. J. Phys. Oceanogr. 31 (3), 827-838.
- 421 Lee, R.W., 2003. Thermal Tolerances of Deep-Sea Hydrothermal Vent Animals From the
- 422 Northeast Pacific. Biol. Bull. 205 (2), 98-101.
- Linke, P., Suess, E., Torres, M., Martens, V., Rugh, W.D., Ziebis, W., Kulm, L.D., 1994. In
- situ measurement of fluid flow from cold seeps at active continental margins. Deep Sea
- 425 Res. 41, 721.
- Luther, G.W., Rozan, T.F., Taillefert, M., Nuzzio, D.B., Meo, C.D., Shank, T.M., Lutz, R.A.,
- 427 Cary, S.C., 2001. Chemical speciation drives hydrothermal vent ecology. Nature 410,
- 428 813-816.

- 429 Martins, I., Colaço, A., Dando, P.R., Martins, I., Desbruyères, D., Sarradin, P.-M., Marques,
- J.C., Serrão-Santos, R., 2008. Size-dependent variations on the nutritional pathway of
- 431 Bathymodiolus azoricus demonstrated by a C-flux model. Ecol. Model. 217 (1-2), 59.
- 432 Mullineaux, L.S., Peterson, C.H., Micheli, F., Mills, S.W., 2003. Successional mechanism
- varies along a gradient in hydrothermal fluid flux at deep-sea vents. Ecol. Monogr. 73
- 434 (4), 523-542.
- Pruis, M.J., Johnson, H.P., 2004. Tapping into the sub-seafloor: examining diffuse flow and
- 436 temperature from an active seamount on the Juan de Fuca Ridge. Earth Planet. Sci.
- 437 Lett. 217 (3-4), 379-388.
- 438 Ramondenc, P., Germanovich, L.N., Von Damm, K.L., Lowell, R.P., 2006. The first
- measurements of hydrothermal heat output at 9°50'N, East Pacific Rise. Earth Planet.
- 440 Sci. Lett. 245 (3-4), 487.
- Ravaux, J., Gaill, F., Bris, N.L., Sarradin, P.-M., Jollivet, D., Shillito, B., 2003. Heat-shock
- response and temperature resistance in the deep-sea vent shrimp *Rimicaris exoculata*.
- 443 J. Exp. Biol. 206 (14), 2345-2354.
- Rona, P.A., Trivett, D.A., 1992. Discrete and diffuse heat transfer atashes vent field, Axial
- Volcano, Juan de Fuca Ridge. Earth and Planetary Science Letters 109 (1-2), 57.
- Sarma, Garimella R., Comte-Bellot, G. 2002. Automated constant voltage anemometer for
- measurements with fluid temperature drifts. Rev. Sci. Instr. 73, n° 3, pp. 1313-1317.
- Sarradin, P.-M., Lannuzel, D., Waeles, M., Crassous, P., Le Bris, N., Caprais, J.C., Fouquet,
- 449 Y., Fabri, M.C., Riso, R., 2008. Dissolved and particulate metals (Fe, Zn, Cu, Cd, Pb) in
- 450 two habitats from an active hydrothermal field on the EPR at 13°N. Sci. Tot. Env. 392
- 451 (1), 119-129.
- 452 Sarrazin, J., Robigou, V., Juniper, S.K., Delaney, J.R., 1997. Biological and geological
- 453 dynamics over four years on a high-temperature sulfide structure at the Juan de Fuca
- 454 Ridge hydrothermal observatory. Mar. Ecol. Prog. Ser. 153, 5-24.
- Sarrazin, J., Juniper, S.K., 1999. Biological characteristics of a hydrothermal edifice mosaic
- 456 community. Mar. Ecol. Prog. Ser. 185, 1-19.
- 457 Sarrazin, J., Juniper, S.K., Massoth, G., Legendre, P., 1999. Physical and Chemical factors
- influencing species distributions on hydrothermal sulfide edifices of the Juan de Fuca
- 459 Ridge, Northeast Pacific. Mar. Ecol. Prog. Ser. 190, 89-112.
- Sarrazin, J., Levesque, C., Juniper, S.K., Tivey, M.K., 2002. Mosaic community dynamics on
- 461 Juan de Fuca Ridge sulfide edifices: substratum, temperature and implications for
- 462 trophic structure. Cah. Biol. Mar. 43, 275-279.
- 463 Sarrazin, J., Sarradin, P.M. and MoMARETO cruise participants., 2006. MoMARETO: a
- 464 cruise dedicated to the spatio-temporal dynamics and the adaptations of hydrothermal
- vent fauna on the Mid-Atlantic Ridge. InterRidge News 15, 24-33.

- Schultz, A., Delaney, J.R., McDuff, R.E., 1992. On the partitioning of heat flux between diffuse and point source seafloor venting. J. Geophys. Res. 97 (B9), 219-314.
- Schultz, A., Dickson, P., Elderfield, H., 1996. Temporal variations in diffuse hydrothermal flow at TAG. Geophys. Res. Lett. 23 (23), 3471-3474.
- Shank, T.M., Fornari, D.J., Von Damm, K.L., Lilley, M.D., Haymon, R.M., Lutz, R.A., 1998.
- Temporal and spatial patterns of biological community development at nascent deepsea hydrothermal vents (9°50'N, East Pacific Rise). Deep-Sea Res. 45, 465-515.
- 473 Shillito, B., Jollivet, D., Sarradin, P.M., Rodier, P., Lallier, F., Desbruyères, D., Gaill, F., 2001.
- Temperature resistance of *Hesiolyra bergi*, a polychaetous annelid living on deep-sea vent smoker. Mar. Ecol. Progr. Ser. 216, 141-149.
- Somero, G.N., Childress, J.J., Anderson, A.E., 1989. Transport, metabolism, and detoxification of hydrogen sulfide in animals from sulfide-rich environments. CRC Critic.
- 478 Rev. Aquat. Sci. 1 (4), 591-614.
- 479 Trivett, D.A., Williams, A.J., 1994. Effluent From Diffuse Hydrothermal Venting.2.
- 480 Measurement Of Plumes From Diffuse Hydrothermal Vents At The Southern Juan de
- 481 Fuca Ridge. J. Geophys. Res. 99 (C9), 18417-18432.
- Truzzi, G. E., Sarma, G. R., Chokani, N. 2002. Constant voltage anemometer operated hot
- wire at subsonic speeds over wide overheats in unsteady flows. Rev. Scient. Instr. vol.
- 484 73, n° 12, pp. 4363-4368.
- Tryon, M., Brown, K., Dorman, L., Sauter, A., 2001. A new benthic aqueous flux meter for very low to moderate discharge rates. Deep Sea Res. 48, 2121.
- Tunnicliffe, V., Garrett, J.F., Johnson, H.P., 1990. Physical and biological factors affecting
- the behaviour and mortality of hydrothermal vent tubeworms (vestimentiferans). Deep
- 489 Sea Res. 37, 103-125.
- 490 Urcuyo, I.A., Massoth, G.J., Julian, D., Fisher, C.R., 2003. Habitat, growth and physiological
- 491 ecology of a basaltic community of *Ridgeia piscesae* from the Juan de Fuca Ridge.
- 492 Deep Sea Res. 50, 763-780.
- 493 Van Dover, C.L., 1990. Biogeography of hydrothermal vent communities along seafloor 494 spreading centers. Tree 5 (8), 242-246.
- 495

Figure captions

496 497

- Figure 1. The flow visualizer is composed of a transparent, 2-cm interval graduated
- 499 pipe mounted on a large cylindrical chamber.
- 500 **Figure 2.** The flow sensor is constituted of two Pt resistive temperature sensors and
- a hot wire embedded in an epoxy paddle. Earth-Ocean Systems Ltd.
- Figure 3. The dual system FLO was deployed on the Tour Eiffel hydrothermal edifice
- 503 during the MoMARETO cruise in 2006. The flow rate is determined by a dual
- approach combining video imagery and flow sensor measurements.
- 505 **Figure 4.** Scheme of the flow sensor calibration device.
- Figure 5. Applied fluid flow velocity versus hot film temperature (Tw) obtained with
- the flow sensor probes in the laboratory at different ambient temperatures (Ta: 17.5)
- 508 to 35.3°C).
- 509 Figure 6. Calculated flow velocity (U) versus real flow speed, measured in the
- laboratory, using the calibration model (eq. 5). The determination coefficient R² is
- 511 0.988.
- 512 Figure 7. Fluid velocity data obtained during the fourth deployment of dive 304
- during the MoMARETO cruise in 2006. The white rectangles (□) represent the flow
- velocities as measured by Observer 2 (OBS2) using video image analyses. To get
- 515 the best "mean" possible and to limit large standard deviations, only the velocity
- values on the stable portion of the curve (**I**) were used to calculate the different
- 517 coefficients. The bold line represents the interval used to calculate the final mean
- sensor flow velocity.
- 519 Figure 8. Mean flow velocity versus mean ambient flow temperature (Ta) as resulted
- from the 14 measurements on the Eiffel Tower edifice. The determination coefficient
- R² is 0.999 for a total number of measurements (n) of 14. The following equation:
- 522 Velocity = 11.566Ta 7.8433 where Ta is the ambient flow temperature (°C)
- describes a best fit to the velocity data.

524

Tables

Table 1. Paired comparisons of fluid flow velocities as measured by three different observers for 6-9 different video sequences. Test 1: Wilcoxon signed rank test for difference in the mean velocity for all particles, in all paired sequences between observers. Test 2: Wilcoxon signed rank test for difference in the velocity for paired particles between observers. V and p-values are given. * indicates that there is a statistical difference (α = 0.05) between two observers.

Wilcoxon signed rank test	OBS1 OBS2	OBS1 OBS3	OBS2 OBS3	
Test 1				
n sequences	9	6	6	
V	15	0	0	
P-values	0.4258	0.03125*	0.03125*	
Test 2				
n particles	104	93	37	
V	1725.5	1216.5	296	
P-values	0.1077	0.8814	0.3519	

Table 2. Temperature and flow measurements acquired during three dives of the MoMARETO cruise. The approximate duration of each sequence is given. The **video flow velocity** was extracted from video image analyses. *Ta* and *Tw* are respectively the ambient and the hot film temperature measured by the flow sensor. The **flow velocity at the sensor level** is obtained using equation 6. The mean **flow velocity at the substratum level** was estimated by dividing the velocity at the sensor level by 37.6 (representing the ratio between the surface area of the chamber (706.9 cm²) and that of the pipe (18.8 cm²). The **flow rate** is directly calculated by multiplying the sensor flow velocity with the cross-sectional area at the sensor level divided by the studied surface area: flow velocity_{sensor} (dm/min) x pipe surface area (dm²)/chamber surface area (m²). SD corresponds to standard deviation.

Dive	Duration	Video flow	Ta (°C)	Tw (°C)	Flow velocity at	Mean flow	Flow rate
	(min ± 0.5 s)	velocity	± SD	± SD	the sensor level	velocity at the	(L min ⁻¹ m ⁻²)
		(mm s ⁻¹) ± SD			$(mm s^{-1}) \pm SD$	substratum	± SD
						level	
						$(mm s^{-1}) \pm SD$	
301	17	161.5 ± 12.5	15.0 ± 0.6	18.9 ± 0.5	164.8 ± 6.8	4.4 ± 0.2	262.9 ± 10.8
	10		16.4 ± 0.3	20.0 ± 0.3	183.6 ± 4.5	4.9 ± 0.1	293.0 ± 7.1
	2		4.7 ± 0.1	9.3 ± 0.2	46.6 ± 1.6	1.2 ± 0.1	74.3 ± 2.5
	7		6.9 ± 0.2	11.4 ± 0.3	71.6 ± 2.6	1.9 ± 0.1	114.2 ± 4.1
	6	151.9 ± 9.5	13.8 ± 0.5	17.5 ± 0.4	151.7 ± 5. 9	4.0 ± 0.2	242.0 ± 9.4
302	8	61.1 ± 9.8	6.2 ± 0.2	11.0 ± 0.3	64.4 ± 2.9	1.7 ± 0.1	102.8 ± 4.6
	10		4.5 ± 0.1	8.7 ± 0.3	41.9 ± 1.8	1.1 ± 0.1	66.2 ± 2.9
	2.5		14.0 ± 0.6	17.9 ± 0.6	153.3 ± 6.7	4.1 ± 0.2	244.6 ± 10.7
	2		6.6 ± 0.1	11.2 ± 0.1	68.8 ± 1.1	1.8 ± 0.1	109.8 ± 1.8
	10	67.7 ± 10.4	6.2 ± 0.2	10.6 ± 0.4	62.8 ± 3.2	1.7 ± 0.1	100.2 ± 5.1
304	0.5	64.2 ± 1.5	6.1 ± 0.2	11.3 ± 0.2	65.7 ± 2.0	1.7 ± 0.1	104.8 ± 3.1
	7	56.8 ± 6.2	5.9 ± 0.2	10.8 ± 0.3	62.0 ± 2.1	1.6 ± 0.1	99.0 ± 3.4
	8	77.9 ± 5.2	7.3 ± 0.1	12.1 ± 0.3	76.9 ± 1.8	2.0 ± 0.1	122.7 ± 2.8
	7.5	111.0 ± 3.7	9.7 ± 0.2	14.3 ± 0.2	104.1 ± 2.5	2.8 ± 0.1	166.0 ± 4.1

Table 3: Review of fluid flow velocities measured in different deep-sea chemosynthetic ecosystems. Modified from Ramondenc et al. (2006). * Equivalent to measurement at sensor level, not calibrated for surface or no information on calibration. **Equivalent to measurement at substratum level.

_	_	1
.)	Э	.)

Authors	Sites	Type of emission	Methods	T °C	Flow velocity	Flow rate
					mm s ⁻¹	
Corliss et al.	Galapagos	Vents	Visual observation			2-10 L s ⁻¹ *
1979			on a vane-type			
			flowmeter			
Converse et	EPR 21°N	Hot vents and	Turbine flowmeter	275-350	700-2400*	150 kg H₂O s ⁻¹
al. 1984		chimneys				
Rona and	Juan de	Discrete	Visual, eddies and	108-326	250-900*	
Trivett, 1992	Fuca Ridge	sources	particles tracking			
		Diffuse		21-226	50-100*	
		sources				
Schultz et al.	_ Juan de	Diffuse flow	Electromagnetic	7-13	70-150**	
1992	Fuca Ridge	(tubeworms)	induction flow			
0: 1 1			meter, time series	200 074	202 2022	
Ginster et al.	Juan de	Hot vents	Turbine flowmeter	296-374	600-6200	
1994	Fuca Ridge	chimneys		005 050	4000 0500	
0 -1- 11 -1 -1	TAGAMI	D:((()-	Maril and Citation	235-350	1300 – 3500	
Schultz et al.	TAG Mid-	Diffuse flow	Medusa (titanium	14±0.5	5.1±0.4**	
1996	Atlantic	Time series	rotor velocity			
Ramondenc	Ridge EPR 9°50'	Lliab	sensor) Visual, eddies and	345-388	100 – 300*	
et al. 2006	N PR 9 50	High temperature	particles tracking	343-300	100 – 300	
et al. 2000	IN IN	venting sites	particles tracking			
		Low		10	40*	
		temperature		10	70	
		diffuse venting				
		sites				
This study	LS- MAR	Low	Visual and	4.7 –	42-184*	66 – 293
, ,		temperature	heated thin film	16.4		L min ⁻¹ m ⁻²
		diffuse	flow sensor		1.1-4.9**	
		venting sites				
Seeps						
Linke et al.	Cascadia		Mechanical mass		0.5 – 10	30 – 1065 m yr ⁻¹
1994	margin		flow meter		(measured	(max 0.03 mm s
			thermistor hot		by the	1)
			bead flowmeter		sensor)	
Tryon et al.	Cascadia		Chemical and		10 – 200 cm	
2001	margin		aqueous transport		yr ⁻¹	
			meter			

Figures




Figure 1




Figure 2.



Figure 3.




Figure 4.




Figure 5.




Figure 6.




Figure 7.




Figure 8.